

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20121011-E44570  
**Report Reference** E44570-19921015  
**Issue Date** 2012-OCTOBER-11

**Issued to:** GEMS SENSORS INC  
1 COWLES RD  
PLAINVILLE CT 06062

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS


Class I, Division 2, Groups A, B, C and D Hazardous Locations, Safe Pak, Part Nos. 144600 and 144800 solid state relays providing intrinsically safe circuits for use in Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III hazardous locations when installed in accordance with manufacturer's installation instructions, Bulletin 121440.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 913, Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III, Division 1, Hazardous (Classified) Locations

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

