



Certificate of Compliance

Certificate: 1217403 (LR 22666-7)

Master Contract: 156011

Project: 2018357

Date Issued: June 4, 2008

Issued to: GEMS Sensors Inc.

One Cowles Rd
Plainville, CT 06062-1198
USA
Attention: Victor Fonseca

The products listed below are eligible to bear the CSA Mark shown



Issued by: James Cotton

Authorized by: David Schaefer, Manager of Certification Services

A handwritten signature in black ink, appearing to read 'David Schaefer'.

PRODUCTS

CLASS 3218 02 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices-For Hazardous Locations

Class I, Groups A, B, C and D:

- "Safe-Pak" switching units, Part No ST-22445, normally open and Part No ST-25872, normally closed, 120V, 60Hz, 5A and Part No ST-25873, normally open, 240V, 60Hz, 5A; hazardous area switch terminals provide an intrinsically safe circuit for remote switches.

Note: These devices are for mounting in suitable enclosures in a non-hazardous area in accordance with and must be fused as indicated in the manufacturer's instructions (Bulletin 54477).



Certificate: 1217403 (LR 22666-7)

Master Contract: 156011

Project: 2018357

Date Issued: June 4, 2008

Class I, Div. 2, Groups A, B, C and D:

- "Safe-Pak" switching units, Model (P/N) ST-25873, normally open, 240V, 5A, 50/60Hz.

Notes:

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 0-M91 - General Requirements - Canadian Electrical Code, Part II

CAN/CSA-C22.2 No. 14-95 - Industrial Control Equipment

CAN/CSA-C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

CSA Std C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations