

CERTIFICATE OF COMPLIANCE

Certificate Number E44570
Report Reference E44570-19691226
Date 2021-August-04

Issued to: GEMS SENSORS INC
1 COWLES RD
PLAINVILLE CT, 06062-1107 US

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

Class I, Division 2, Groups A, B, C and D.
Part Nos. ST-22445, ST-25872, ST-25873, and ST-41705.
Providing intrinsically safe circuits for use in Class I,
Division 1, Groups A, B, C and D; Class II, Division 1,
Groups E, F and G hazardous locations when installed in
accordance with manufacturer's installation instructions,
Bulletin No. 54477.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E44570
Report Reference E44570-19691226
Date 2021-August-04


This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Standard(s) for Safety:

UL 121201 "Non-incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations"

UL 913 INTRINSICALLY SAFE APPARATUS AND ASSOCIATED APPARATUS FOR USE IN CLASS I, II, AND III, DIVISION 1, HAZARDOUS (CLASSIFIED) LOCATIONS-

UL 61010-1, SAFETY REQUIREMENTS FOR ELECTRICAL EQUIPMENT FOR MEASUREMENT, CONTROL, AND LABORATORY USE - PART 1: GENERAL REQUIREMENTS.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

