CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference Issue Date 20121011-E44570C E44570-19820223 2012-OCTOBER-11

Issued to:

GEMS SENSORS INC 1 COWLES RD PLAINVILLE CT 06062

This is to certify that representative samples of

PROCESS CONTROL EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS

Class I, Division 2, Groups A, B, C and D hazardous locations programmable "Safe-Pak" relays, Part Nos. ST-54820, -54825, -54845, -54850 and -54860 having circuits which are intrinsically safe for use in hazardous locations; Class I, Division 1, Groups A, B, C and D, Class II, Division 1 Groups E, F and G when connected in accordance with manufacturer's installation instructions, Bulletin No. 51660.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:UL 913, Intrinsically Safe Apparatus & Associated
Apparatus for Use in Class I, II, & III, Division 1, Hazardous
(Classified) LocationsAdditional Information:See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: U with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carney

William R. Carney, Director, North American Certification Programs



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, plea contact a local UL Customer Service Representative at <u>www.ul.com/contactus</u>