

CERTIFICATE OF COMPLIANCE

Certificate Number 20121011-E44570D
Report Reference E44570-19830107
Issue Date 2012-OCTOBER-11

Issued to: GEMS SENSORS INC
1 COWLES RD
PLAINVILLE CT 06062

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS


Class I, Division 2, Groups A, B, C and D hazardous locations Part Nos. 64098, 64101, 66098 and 66101 "Safe-Pak" switching devices having intrinsically safe circuits for Class I, Division 1, Groups A, B, C and D hazardous locations when connected in accordance with manufacturer's installation instructions, Bulletin Nos. 64557 and 64558.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 913, Intrinsically Safe Apparatus & Associated Apparatus for Use in Class I, II, & III, Division 1, Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

