

# Warrick Series 1 Conversions to Series 16 and Series 26

LWCO: Low water cutoff on a boiler, use Series 26 Relay

Non LWCO: Non low water cut off on a boiler. Use Series 16 Relay.

These part numbers will include the retrofit plate so they will fit within the same footprint and mounting holes as the Series 1 relays.

We no longer offer a Normally Open (NO) reset switch option.

Series 1 Relays cannot be within the same tank as current Series 16 and 26 Relays due to different voltages.

Series 1 P/Ns	LWCO	Non LWCO	Notes
1D1D0	26B1D0R	16B1D0R	
1D2D0	26B2D0R	16B2D0R	
1D1E0	26C1D0R	16C1D0R	
1D2E0	26C2D0R	16C2D0R	
1C1D0	26B1D0R	16DB1D0R	
1C2D0	26B2D0R	16DB2D0R	
1C1E0	26C1D0R	16DC1D0R	
1C2E0	26C2D0R	16DC2D0R	
1E1D0	26B1D0R	16DB1D0R	
1E2D0	26B2D0R	16DB2D0R	
1E1E0	26C1D0R	16DC1D0R	
1E2E0	26C2D0R	16DC2D0R	

1G1D0	26B1D0R	16DB1D0R	
1G2D0	26B2D0R	16DB2D0R	
1G1E0	26C1D0R	16DC1D0R	
1G2E0	26C2D0R	16DC2D0R	
1F1D0	26B1D0R	16DB1D0R	1F Series has 3 'NO' contacts so you may require an additional Series 16 Relay
1F2D0	26B2D0R	16DB2D0R	
1F1E0	26C1D0R	16DC1D0R	
1F2E0	26C2D0R	16DC2D0R	
1H1D0	26B1D0R	16DB1D0R	
1H2D0	26B2D0R	16DB2D0R	
1H1E0	26C1D0R	16DC1D0R	
1H2E0	26C2D0P	16DC2D0R	
1J1D0	26B1D0R	16DB1D0R	1J Series has 3 'NC' contacts so you may require an additional Series 16 Relay
1J2D0	26B2D0R	16DB2D0R	
1J1E0	26C1D0R	16DC1D0R	
1J2E0	26C2D0R	16DC2D0R	